

How current TLAF Methodology is not fit for purpose

Presentation to RAs Workshop on TLAFs
26 July 2010



Presentation

- Background
 - Locational Signals
- Impact on Cork Generators
- Report on Actual System Losses
 - Study methodology
 - Results & Findings
- Overview of all-island attributed losses
- Conclusions

Background

- Plant located in Aghada in response to clear locational signals
 - EirGrid signalled that additional generation needed in Cork
 - Having fully committed, the locational signals changed dramatically

Adobe Reader - [Eirgrid.pdf]

File Edit View Document Tools Window Help

Save a Copy Search Select 60% Help


Adobe Reader 7.0

Layers Pages Attachments Comments

Locational Considerations for Prospective Generators

Timothy Hurley
Commercial & Regulation

EirGrid Annual Conference
Croke Park, 19th Oct 2006

 www.eirgrid.com

1 of 18



Adobe Reader - [Eirgrid.pdf]

File Edit View Document Tools Window Help



Save a Copy Search Select 60% Help

Adobe Reader 7.0

Locational Example, 2006

- Common Assumptions
 - 400MW Generator
 - 90% Load Factor
 - Energy Price, 2006 BNE €66/MWh

Dublin	Cork
Approx TLAF = 0.985	Approx TLAF = 1.012
Value of energy sold = €205.0M	Value of energy sold = €210.6M
Approx TUoS = €4.0M	Approx TUoS = €2.6M
Total Annual Difference €7.0M	

www.eirgrid.com

15 of 18



Magnitude of Volatility in Cork

2007 Winter Day TLAF

1.044

TLAF when committed

2010 Winter Day TLAF

0.917

TLAF when connected



Report on Actual System Losses

- ESB believes indicated impact is not warranted
- Report commissioned with the objective:

To establish true impact of new Cork Generation on system losses in Ireland


- Report demonstrates unequivocally that impact is not credible.




Study Methodology

- Data and assumptions in line with standard TSO practice
- PSS/e loadflow studies
- AD2/BGE output reduced in 20MW steps
- Alternative Generation brought on
- System losses established


Total System Losses (MW)




Total System Losses (MW)



Total System Losses (MW)



Total System Losses (MW)




Report Findings

- Observations
 - AD2/BGE generation has minimal impact on actual system losses.
 - The first 385MW of generation from AD2/BGE actually reduce system losses.
 - The first 800MW of generation from AD2/BGE are loss free in relative terms.
 - Irrespective of output from Cork generators, minimum system losses cannot be reduced below ~50MW.
- Conclusion
 - Methodology is not reflective of actual impact on system.

Current TLAF methodology is broken!

* Published by TSOs with draft 2010 TLAFs in November 2009



Overall Conclusions

- TLAF methodology is not fit for purpose
 - Works at the margins
 - Makes absolutely no sense to apply same TLAF to all of the output
- Unjustifiable distortion of market
 - Certain plants disproportionately penalised
 - Cork CCGT plants covering all of transmission system losses in Rol
 - Significant monetary impact for Aghada CCGT
 - Certain plants disproportionately rewarded
 - Significant change to 2010 TLAFs granted benefits without justification
- Broken TLAF methodology resulting in uneconomic dispatch of plant, unnecessary CO2 emissions.

Not delivering value for Customer

